

RESULTS:


The initial ambient temperature was 57°F

Hose Stream Test: No holes formed in the unexposed side of the sample after being exposed to the hose stream for 24 seconds.


F Rating: 120 minutes

The sample met the acceptance criteria of the "F Rating" for 120 Minutes per ASTM E814/UL 1479 specifications.

The time-temperature data are contained on the following pages.



Neil Schultz
Executive Director



REVISION 1.0: Added "The furnace maintains a minimum positive pressure differential of 0.01 inches of water column" under " PROCEDURE.